

**TAMILNADU FIRE - RESCUE SERVICE DEPARTMENT**  
**NO OBJECTION CERTIFICATE**

R.C No : 351 / V / RDH / 2023

Date:24 .06.2023

Sub : Fire and Rescue Service - Fire and Rescue Station Redhills – Issuing Of No  
Objection Certificate – Functioning the School

Ref : 1. G.O/ M.s 122 Dt : 14-09-2004/ Dept. of School Education, Tamil Nadu.

2. G.O/ M.s 123 Dt : 14-09-2004/ Dept. of School Education, Tamil Nadu.

3. Application Received from Correspondent of ALPHA INTERNATIONAL  
SCHOOL Dated on 22.06.2023.


\*\*\*\*\*

Based on the reference in the G.O's cited (1) & (2) Mr. K.SEENIVASAGAN  
Station Officer Redhills , Inspected the school in the name of ALPHA INTERNATIONAL  
SCHOOL, No.48,49, SIVANTHI ATHITHANAR NAGAR, PUZHAI, CHENNAI -  
600066. on 23-06-2023. Here I issue this NO OBJECTION CERTIFICATE subject to the  
condition noted there on and such conditions as may be prescribed. The Fire Fighting  
Equipment were found to be in position and Regular licence has to be obtained from the  
competent authority.

**CONDITIONS**

1. This License is valid for One year from the date of issue.
2. Fire safety systems should be maintained in Good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
  - a. Building occupancy capacity should not be more than 4 people per sq. Meter as per national Building code-2005.
  - b. The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
  - c. As per Para 6.3 of the BIS standards IS 14435 : 1997 if the classrooms have only one entrance, the capacity of the classrooms shall have to be limited to 45 students.
  - d. Periodical maintenance and care should be taken to maintain all fire protection equipment's.
  - e. Mock drill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Chennai City Sub – Urban District at Ambattur.



  
STATION OFFICER  
FIRE - RESCUE STATION  
REDHILLS, CHENNAI - 600 052

To

**ALPHA INTERNATIONAL SCHOOL,**  
**No.48,49,SIVANTHIATHITHANAR NAGAR,**  
**PUZHAI, CHENNAI - 600066..**

Copy to:

1. The District Officer (Chennai – Sub - Urban),  
TamilNadu Fire & Rescue Service, Chennai – 58.